

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7165-0900:106 Page 1 of 1

CATEGORY: Control Unit (Non High-Rise)

LISTEE: Fike Protection Systems, 704 S. 10th St., Blue Springs MO 64015
Contact: *Sean Titus (816) 229-3405 ext 281

DESIGN: Models 10-201 INTELLA-SCAN and INTELLA-SCAN II control units. Local, noncoded, manual and automatic, releasing device and sprinkler supervisory service. Refer to listee's data sheets for detailed product description and operational considerations. Basic components:

10-1774 ¹	10-1780A ¹	10-1779A ¹	10-2110 ²
10-2111 ²	10-2101 ²	10-1585	10-1753A
*10-1794B	*10-1796A	*10-1985B	*10-2095
*10-2096	*10-2097	10-1775A	*10-201-E1 ²
*10-201-E2 ²	*10-201-E4 ²	55-003	55-005
*55-013	*10-048	10-047	10-1961
10-2009	10-2010	55-006	55-012
55-007	55-010		

(¹): Limited to Intella-Scan system;(²): Limited to Intella-Scan II system

OPTIONS: Refer to listee's data sheet for required/optional accessories. When required, accessories shall be CSFM listed.

INSTALLATION: In accordance with listee's printed installation instructions and applicable codes and ordinances.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as a fire alarm control unit for use with separately listed compatible initiating and indicating devices.

This control unit does not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition is required, the control unit must be used with appliances that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

Rev. 06-11-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 20, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager